




MUNICIPAL CORPORATION OF DELHI
OFFICE OF DEPUTY HEALTH OFFICER
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2023/D- 1563

Dated 03/08/2023

1. Name of the School NAV GIAN DEEP PUBLIC SCHOOL
2. School Address A-1/ 66, VIJAY ENCLAVE PALAM DABRI ROAD NEW DELHI
3. No. of Shift ONE Timing 07:30 AM TO 02:00 PM
4. No. of Students: Boys-397 Girls-219 Total = 616
5. No. of Staffs: MALE 09 Female 24 Total = 33


Details of Accommodations present in School

- | | |
|---|-------------------------------------|
| 1. Floor Space in the Classroom Sufficient/insufficient | SUFFICIENT |
| 2. The Classrooms are Well Lighted/ill lighted | WELL LIGHTED |
| 3. The Classrooms are Well Ventilated/ill ventilated | WELL VENTILATED |
| 4. The Classrooms are kept / Not kept Neat & Clean: | NEAT AND CLEAN |
| 5. The Building requires/does not required Whitewash etc. | NOT REQUIRED |
| 6. The Drinking Water is Wholesome/Not wholesome | WHOLESOME |
| 7. The Latrine arrangement is Sanitary/Insanitary | SANITARY FROM HEALTH POINT OF VIEW. |


No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is SUFFICIENT
2. One latrine for 40 male student is required so total is SUFFICIENT
3. Separate Toilet arrangement for staff present: Yes/No YES SEPARATE EXISTS FOR STAFF.
4. The Overall facilities: Good/ Adequate/Inadequate GOOD FROM HEALTH POINT OF VIEW.

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard


Deputy Health Officer
Najafgarh Zone
Deputy Health Officer
Najafgarh Zone, MCD

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)


MANAGER 24/7/23
NAV GIAN DEEP SR. SEC. PUBLIC SCHOOL
(Recognised By Directorate of
Education & Affiliated To C.B.S.E.)
Block A/66, Vijay Enclave, New Delhi-45



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041



International Year
of Cooperatives
Cooperatives Build a Better World

Water sample collected from "Nav Gian Deep Public School" A-1 Block, 66, Vijay Enclave, Dabri Palam Road, New Delhi - 110045 vide challan No- 298 Dated - 18.03.2025.

S1: DJB supply water at above site

S2: Drinking Point (R.O.) at above site

THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY.

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	21.03.2025	21.03.2025
2.	Date of Analysis	-----	--	--	22.03.2025	22.03.2025
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	2.8	1.6
6.	PH value	-----	6.5	8.5	7.64	7.4
7.	Electrical Conductivity	µmho/cm	--	--	357	110
8.	Total dissolved solids	mg/l	500	2000	228.1	71.5
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	94	40
11.	Total Hardness	mg/l	200	600	128	38
12.	Calcium Hardness	mg/l	--	--	76	22
13.	Magnesium Hardness	mg/l	--	--	52	16
14.	Calcium as Ca	mg/l	75	200	30.4	8.8
15.	Magnesium as Mg	mg/l	30	100	12.48	3.84
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	2.2	1.6
19.	Sulphate	mg/l	200	400	40	06
20.	Chloride	mg/l	250	1000	16	10
21.	Dissolved Iron	mg/l	1	N.R.	0.08	0.02
22.	Fluoride	mg/l	1	1.5	0.26	0.14
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.40	NIL
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS: As per tested parameters, Samples S-1 & S-2 can be used for drinking purpose.

S. Pandey
ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41

[Signature]
BACT.

[Signature]
A/CHEMIST